Bell & Gossett

a **xylem** brand

JOB:	REPRESENTATIVE:	
UNIT TAG:	ORDER NO.	DATE:
ENGINEER:	SUBMITTED BY:	DATE:
CONTRACTOR:	APPROVED BY:	DATE:
There alle® De		

Thermoflo[®] Balancer

DESCRIPTION

The Thermoflo Balancer is an indicating flow meter and balancing device for measuring and balancing hydronic circuits. Installed in each circuit of a system, it permits simple balancing to meet design flow conditions.

CONSTRUCTION

Body: cast iron Indicating Device: stainless steel Glass Scale: borosilicate.



SCHEDULE

			FLOW RANGE			
	MODEL	SIZE	GALLONS PER	LITERS PER		
PART NUMBER	NUMBER	INCHES	MINUTE	MINUTE	TAGGING INFORMATION	QUANTITY
127001	TB-3/4	3/4	1 to 5	4 to 19		
127002	TB-1	1	2 to 10	5 to 38		


PERFORMANCE CHARACTERISTICS

WORKING PRESSURE - 125 P.S.I.G. MAX. OPERATING TEMP. - 250°F

Note: System pH must be maintained between 7 and 9. As it is true of all visual flow indicators precautions against damage from accidental glass breakage should dictate balancer locations.

DIMENSIONS & WEIGHTS

MODEL NO.	CONNECTION INCHES (NPT)	DIAMETER IN (MM)	LENGTH IN (MM)	APPROX SHPG WT LBS (KG)
TB-3/4	3/4	2 (51)	9-1/4(235)	4 (1.8)
TB-1	1	2 (51)	9-1/4(235)	4 (1.8)



TYPICAL SPECIFICATIONS:

Furnish and install as shown on plans, a ______ "NPT (select one: 3/4" or 1"), visual flow indicator/circuit balancer with a stainless steel flow indicating mechanism, integral nonferrous flow balancing device and cast iron body. The flow indicator/balancing device shall be designed for 125 psig working pressure at a maximum fluid temperature of 250°F, and is designed for replacement of the indicating mechanism without breaking piping connections.

Each flow indicator/balancing device shall be Xylem Bell & Gossett Model No. TB-_____Thermoflo Balancer.

Xylem Inc. 8200 N. Austin Avenue Morton Grove, IL 60053 Phone: (847)966-3700 Fax: (847)965-8379 www.bellgossett.com



Bell & Gossett is a trademark of Xylem Inc. or one of its subsidiaries. $\ensuremath{\mathbb{C}}$ 2013 Xylem Inc.

SUBMITTAL

A-427B