

GENERAL INFORMATION, INSTALLATION AND OPERATION SPECIFICATIONS

1.0 <u>GENERAL REQUIREMENTS</u>

- 1.1 Provide and install BoilerMagXL in accordance with manual specifications
- 1.2 All work is to be performed in neat workmanship like manner compliant with all local code authorities
- 1.3 BoilerMagXL is to be used in medium-sized systems working at up to 174psi (145 psi if using automatic air vent)


2.0 PRODUCT DATA


PFR	FOR	MA	
FEN	FUR	IVIAI	NCE

Magnetic performance	4,000 Gauss
	Patented Micromag style core
Volume	0.37 gal (1.4 litres)
Pressure	174 psi (12 Bar) operating pressure
	(145 psi (10 Bar) if using automatic air vent)
Flow rate	28 gpm (6 m³/h)
Collection Capacity	2.2 lbs (1 kg)
Temperature	41-302°F (5°C to 150°C)
	(212°F (100°C) if using automatic air vent)

MATERIALS/CONSTRUCTION

Magnet material	Rare Earth Neodymium Iron Boron	
Magnet grade	N42SH high intensity	
Mesh filter	1mm, quick release mesh (for cleaning)	
Housing Cartridge	304 stainless steel 304 stainless steel	
Fasteners	Lid 4x M8 domed nuts Drain plug1/2″ NPT	
Surface Finish	Powder coated	
Ports	1½" NPT	
O Ring Seal	Viton BS244	
INCLUDES	Additional Automatic Air Vent that has been packaged along with unit separately. The auto-vent will automatically release the trapped air maintaining heating efficiency	
OPTIONS	11⁄2" BSP	
WARRANTY	Industry leading 10 years	






3.0 INSTALLATION

- 3.1 BoilerMagXL is typically installed on the return circuit as close to the boiler as possible
- 3.2 BoilerMagXL can be installed using flexible hoses or hard piped
- 3.3 No external power sources required for this product
- 3.4 All supply lines are to be isolated prior to any cleaning or maintenance actions

4.0 PRESSURE DROP DATA

BMXL		
Pressure Differential (psi)		
0		
0.08		
0.11		
0.13		
0.16		
0.20		
0.26		
0.29		



*****GAUSS:** The gauss is the unit of measurement of magnetic flux density



v3

BoilerMag 442 Millen Road, Unit #9, Stoney Creek, ON L8E 6H2 sales@eclipsetoolsinc.com www.boilermag.com/na